



**CARTER WATKINS**  
**ASSOCIATES**  
**A R C H I T E C T S , I N C .**

---

DATE: JUNE 03, 2009  
TO: ALL BIDDERS  
RE: SITE DEVELOPMENT PACKAGE WALTON COUNTY TOWN HALL, FIRE STATION, DDS

**ADDENDUM #2**

---

The following information provided in this Addendum shall supersede all information provided in the Construction Documents in regard to the affected items. This Addendum shall become part of the Construction Documents for the above project and shall be acknowledged by each bidder on the bid form.

- Item 1: **BIDS WILL NOW BE DUE ON JUNE 16, 2009 AT 2:00 P.M.**
- Item 2: Heavy Duty paving is to be as shown on the drawings for the two CDL Courses. It shall be 8" base, 3" binders and 1 1/2" topping.
- Item 3: Contractor will not be responsible for work outside the Limits of Disturbance as shown. Any land cleared by the County outside of these limits will not be part of this contract.
- Item 4: Revised Documents will be released (with minor notes/revisions) in Addendum # 3.

**END OF ADDENDUM**